



**NOTE:**

1. THIS DETAIL SHOULD BE USED ONLY WHERE THE DECK IS STRUCTURALLY SUPPORTED OR OTHERWISE SECURELY CONNECTED TO THE OUTSIDE WALL. MINIMUM FLASHING HEIGHT IS 8" ABOVE TOP OF SURFACING. DO NOT TORCH MODIFIED BITUMEN MEMBRANE DIRECTLY TO WOOD BLOCKING AND CANT; TORCH BACK SIDE OF MEMBRANE AND THEN POSITION IN PLACE.

2. ALL MEMBRANE BASE FLASHINGS MUST BE PROTECTED FROM DAMAGE BY MEANS OF METAL (MINIMUM 24 GAUGE COPPER OR 0.032" ALUMINUM) COUNTERFLASHING EXTENSIONS THAT PROVIDE 100% COVERAGE OF THE BASE FLASHINGS TO BELOW THE TOP OF THE TRAFFIC SURFACING.



**RUBEROID**  
Modified Bitumen Roofing Systems

CUSTOM SERIES

## BASE/CURB FLASHING

DRAWING #

301

SCALE

N.T.S.

SYSTEM

PD

ISSUE/ REVISION DATE

9-20-15